



224

REC'D

MAR 11 2013

APCC

Farabee Mechanical Inc.

**P.O. Box 1748
Hickman, NE 68372-1748
Phone (402) 792-2612
Fax (402) 792-2712**

6 March 2013

KDHE Bureau of Air & Radiation
RICE NESHAP ZZZZ
1000 SW Jackson, Suite 310
Topeka, KS 66612-1366

Attn: Javier Ahumada

Dear Javier,

For LaCrosse Municipal Power Plant, LaCrosse, KS, please find enclosed:

- Revised Notice of Applicability

Please note that LaCrosse originally sent a Notice of Applicability, this revision includes the engine information.

Should you have any questions, I can be reached by email at
farabeecsm@inebraska.com.

Respectfully,

Farabee Mechanical, Inc.

Donna Oehm

Donna Oehm
Client Services Manager

cc: EPA REGION VII (IA NE KS MO)
DIRECTOR, AIR AND WASTE MANAGEMENT
RE: RICE NESHAP ZZZZ
11201 RENNER BLVD
LENEXA KS 66219

LaCrosse Municipal Power Plant, Duane Moeder

FMI

PO Box 1748

Hickman NE 68372-1748

Phone: (402) 792-2612

Fax: (402) 792-2712

Initial Notification of Applicability

National Emission Standards for Hazardous Air Pollutants:

Stationary Reciprocating Internal Combustion Engines

40 CFR part 63, subpart ZZZZ

- ☒ Yes, I am subject to 40 CFR Part 63 Subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS Code(s): 2211 "Electric Power Generation"

Compliance Date: ☒ Existing Source: May 3, 2013
☐ New/reconstructed source: upon initial startup

| | | | |
|-------------------------------------|--------------------------------------|--------------|---------|
| Company Name: | LaCrosse Municipal Power Plant | | |
| Facility Name (if different): | | Facility ID: | 1650001 |
| Facility Physical Location Address: | 202 E. 9th St. LaCrosse, KS 67548 | | |

My facility is a: ☒ Area Source ☐ Major Source

| | | | |
|-------------------------------------|--|--|--|
| Owner name / title: | City of LaCrosse Duane Moeder, City Manager | | |
| Owner/Company address: | PO Box 339 LaCrosse, KS 67548 | | |
| Owner telephone number: | (785) 222-2511 | | |
| Owner email address (if available): | dmlax@gbta.net | | |
| Person to Contact: | | | |
| Name / Title: | Roland Holopirek, Electric Superintendent | | |
| Telephone Number: | (785) 222-2512 | | |
| Email address (if available): | | | |

FMI

PO Box 1748

Hickman NE 68372-1748

Phone: (402) 792-2612

Fax: (402) 792-2712

Initial Notification of Applicability

National Emission Standards for Hazardous Air Pollutants:

Stationary Reciprocating Internal Combustion Engines

40 CFR part 63, subpart ZZZZ

| Brief description of the stationary RICE at the facility, including number of engines and the site-rated HP of each engine: | | | |
|---|--|---------------|---------|
| Unit 1 | Fairbanks-Morse 38DD8-1/8 Serial #970133 | non-emergency | 1600 hp |
| Unit 2 | Fairbanks-Morse 38DD8-1/8 Serial #970418 | non-emergency | 1600 hp |
| Unit 5 | Enterprise DGSR 36, Serial # 69001 | non-emergency | 2114 hp |
| Unit 6 | Fairbanks-Morse 38TD8-1/8 Serial #970292 | emergency | 2880 hp |

I hereby certify that the information presented herein is correct to the best of my knowledge.



(Signature)

Duane Moeder, City Manager

(Printed Name/Title)

3-6-13

(Date)

(785) 222-2511

(Telephone Number)

****Return both pages (signed) to FMI via fax or email: farabeecsm@inebraska.com**